

Government of Bihar
Public Health Division Muzaffarpur
Water Quality Testing Report

District- Muzaffarpur				Testing date - 12.03.2025				Sample Collected by : School Staff										Received Sample on date : 12.03.2025			
SL. No.	Block	Location of Source	Type of Source	Parameters tested										Total Coll.							
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate		Fluoride	Arsenic					
1	KUDHANI	PREMIER ACADEMY, Basauli, Muzaffarpur	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1					
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-					
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-					

Memo No. - 528 Muzaffarpur, Dated - 17-03-2025

Copy to Principal Premier Academy, Basauli, Kudhani, Muzaffarpur to inform regarding reference to his letter No. - PA/28/2025

Dated :- 12/03/2025


Lab Assistant


Chemist


Assistant Engineer
P.H. Division, Muzaffarpur

ASSISTANT ENGINEER
PH DIVISION
MUZAFFARPUR